

Dianne Boisvert

Subject: FW: [Ext]RE: 20 Henry Graf Jr Road - Proposed Development

From: Steve Bradbury
Sent: Monday, May 11, 2020 10:21 AM
To: McKenzie, C. Bradley; Erik Schoumaker
Cc: Katelyn E. Sullivan; Andrew Port
Subject: RE: [Ext]RE: 20 Henry Graf Jr Road - Proposed Development

Hi Katelyn:

We have worked out our issues with Eric and can now support this project. Our pumper truck can navigate with out issue. The DPW will be replacing the hydrant that they removed on Graf Rd across the street from the entry to this project. Eric will be adding a yard hydrant for the fire department connection.

thanks

Deputy Chief Bradbury

From: McKenzie, C. Bradley [BMckenzie@mckeng.com]
Sent: Monday, May 11, 2020 9:27 AM
To: Erik Schoumaker; Steve Bradbury
Cc: Katelyn E. Sullivan; Andrew Port
Subject: [Ext]RE: 20 Henry Graf Jr Road - Proposed Development

external e-mail use caution opening

Hi Katelyn/Andy,

Please see correspondence below from Deputy Chief Bradbury.

We are in the process of coordinating the reconfiguration of the domestic water and fire service with the Water Dept. and will forward revised plans when completed.

Regards,

Bradley C. McKenzie, P.E.
President



Assinippi Office Park
150 Longwater Drive, Suite 101
Norwell, MA 02061

P: 781.792.3900
F: 781.792.0333
C: 781.520.9713



Please consider the environment before printing this email!

CONFIDENTIALITY NOTE: This message and the documents accompanying this transmission may contain information from McKenzie Engineering Group, Inc. which is confidential or privileged information. The information is intended to be for the use of the individual or entity named on this transmission. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the contents of this information is prohibited. If you have received this e-mail in error, please notify us by telephone immediately and kindly delete the messages and attachments.

From: Erik Schoumaker <eschoumaker@mckeng.com>
Sent: Monday, May 11, 2020 9:02 AM
To: sbradbury@cityofnewburyport.com
Cc: McKenzie, C. Bradley <BMckenzie@mckeng.com>
Subject: 20 Henry Graf Jr Road - Proposed Development

Good Morning Deputy Chief Bradbury,

Thanks again for the call this morning to discuss the site development at 20 Henry Graf Jr. Road.

As discussed it is great news that a pumper truck can navigate the site efficiently, and I've attached the previously submitted Fire Truck Turning Plan showing the movement for a ladder truck. We are currently in the process of sizing the water service for the field hydrant w/ the Water Department.

Please let me know if there anything else you need from us for your Department's approval of the Site Plans.

Regards,

Erik Schoumaker, E.I.T.
Project Engineer



Assinippi Office Park
150 Longwater Drive, Suite 101
Norwell, MA 02061
P: 781.792.3900
F: 781.792.0333



Please consider the environment before printing this email!

CONFIDENTIALITY NOTE: This message and the documents accompanying this transmission may contain information from McKenzie Engineering Group, Inc. which is confidential or privileged information. The information is intended to be for the use of the individual or entity named on this transmission. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the contents of this information is prohibited. If you have received this e-mail in error, please notify us by telephone immediately and kindly delete the messages and attachments.